

COOL ROOF RATING COUNCIL

NOTIFICATION OF PRODUCT RATING

Notification Provided By:
Cool Roof Rating Council
2435 N. Lombard St.
Portland, OR 97217

Notification Provided To:
SINA&S
79, Haeryongsandan 5-ro, Haeryong-myeon,
Suncheon-si, Jeollanam-do 58022

Product Brand:	Cool Running-Cool Roof	Product Type:	Coating
Product Model:	Cool Roof/CR-1000	Initial SRI:	111
Company:	SINA&S	3 Year SRI:	91*
Contact Name:	Joomi Yoo	Slope Types:	Low, Steep
Telephone:	+82-10-3520-7234	Color:	Bright White



	<u>Initial</u>	<u>Weathered</u>
Solar Reflectance	0.88	0.74*
Thermal Emittance	0.86	0.86*
Rated Product ID	1384-0001	
Licensed Manufacturer	1384	
Classification	Standard Product	

Cool Roof Rating Council ratings are determined for a fixed set of conditions, and may not be appropriate for determining seasonal energy performance. The actual effect of solar reflectance and thermal emittance on building performance may vary. Manufacturer of product stipulates that these ratings were determined in accordance with the applicable Cool Roof Rating Council procedures.

The Cool Roof Rating Council (CRRC), an ISO 17065 accredited organization, has reviewed the test results data provided by a CRRC-approved ISO 17025 testing laboratory and has determined this roofing product meets the requirements described in the ANSI/CRRC S100 Standard and the CRRC-1 Program Manual. This Notification of Rating is subject to all terms and conditions of the Licensee Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.

The Notification of Rating certificate for the approved initial ratings is valid until an updated certificate is issued by the CRRC that includes the approved three-year aged ratings. The certificate with the approved three-year aged ratings is valid until either the CRRC or Licensee removes the product from the CRRC Rated Products Directory.

***CRRC Rapid Ratings:** These are interim laboratory-aged values that simulate weathered values. These values will be replaced with the measured three-year aged values upon completion of the weathering process. SRI values calculated using Rapid Ratings may change once the aged rating replaces the interim rating.

Application/Technical Review
Auditor

Application/Technical Reviewer

Management Approval

08/18/2021

Certificate Date